



# KINSTON PUBLIC SERVICES

Buildings & Grounds, Business Office, Electric, Engineering, Environmental Services,  
Fleet Maintenance, Meter Reading, Stormwater, Streets, Wastewater, and Water



*Kinston, the right place ... Kinston Public Services, the right choice.*

## City of Kinston Annual Operations and Performance Report 2012

### **Kinston Regional Water Reclamation Facility (KRWRF)**

NPDES	# NC0024236
Design Capacity	11.85 Million Gallons
Treatment Type	Johannesburg Process
Service Date	2006

#### **Facility Comments:**

The last annual inspection report for the Kinston Regional Water Reclamation Facility, dated December 15, 2011, was found to be in compliance with its discharge permit. There were no Notices of Violation during calendar year 2012. There was one (1) Notice of Deficiency letter (NOD-20120LV-0072) received concerning the City's spray irrigation fields. It was noted that two effluent concentrations for Fecal Coliform were above the daily maximum effluent limits for the City's spray irrigation permit WQ0029289. These incidents were fully investigated and it was concluded that the plant's UV disinfection system was not properly disinfecting to the levels required for spray irrigation though they met the treatment plant's NPDES discharge limits.

### **SANITARY SEWER COLLECTION SYSTEM**

During calendar year 2012, the collection system reported zero (0) sanitary sewer overflows (SSO's).

Any spill of 1,000 gallons or more and any reaching surface waters are required to be reported to the DWQ.

The last annual inspection report for the collection system dated August 27, 2010. The North Carolina Division of Water Quality did not perform an inspection for the collection system during calendar year 2011 or 2012.

# Responsible Person Contact Listing

## General:

Rhonda Barwick - Public Services Director	252-939-3303
Steve Miller – Assistant Public Services Director	252-939-3285
Brian Lucas - Water Resources Manager	252-939-3316

## Stormwater Utility:

Brian Lucas - Water Resources Manager	252-939-3316
Gilbert Aceveno - Street Superintendent	252-939-3314

## Water Reclamation (Wastewater Utility):

Kenneth R. Stevens, Jr. - Water Reclamation Facility Superintendent (ORC)	252-939-3375
Swindell Flowers - Residual Management Coordinator (ORC-Land Application)	252-939-3248
Dan Daniels - Water Operations Superintendent (ORC - Wastewater Collections)	252-939-3299

## Water Utility:

Joey Pittman - Water Production Superintendent (ORC-Wells)	252-939-3286
Dan Daniels - Water Operations Superintendent (ORC - Distribution)	252-939-3299
Kelvin Harrison - Water Production Supervisor (ORC-Cross Connection)	252-939-3156