



KINSTON PUBLIC SERVICES

Buildings & Grounds, Business Office, Electric, Engineering, Environmental Services,
Fleet Maintenance, Meter Reading, Stormwater, Streets, Wastewater, and Water



Kinston, the right place ... Kinston Public Services, the right choice.

City of Kinston Annual Operations and Performance Report 2013

Kinston Regional Water Reclamation Facility (KRWRF)

NPDES	# NC0024236
Design Capacity	11.85 Million Gallons
Treatment Type	Johannesburg Process
Service Date	2006

Facility Comments:

The last annual inspection report for the Kinston Regional Water Reclamation Facility, dated July 24, 2013, was found to be in compliance with its discharge permit. There were no Notices of Violation during calendar year 2013.

SANITARY SEWER COLLECTION SYSTEM

During calendar year 2013, the collection system reported one (1) sanitary sewer overflows (SSO's).

Any spill of 1,000 gallons or more and any reaching surface waters are required to be reported to the DWQ.

On December 15, 2013, the City of Kinston had a wastewater spill of an estimated 1,000 gallons from a manhole near 524 Linden Avenue in Kinston, NC. The untreated wastewater spilled into a ditch which feeds the Adkins Branch. This spill was caused by grease in the sewer line and excessive rainfall.

The City of Kinston Public Services Department relieved the blockage, cleaned the surrounding area and notified the Division of Water Quality.

The last annual inspection report for the collection system dated August 27, 2010. The North Carolina Division of Water Quality did not perform an inspection for the collection system during calendar year 2011, 2012 or 2013.

Responsible Person Contact Listing

General:

Rhonda Barwick - Public Services Director	252-939-3303
Steve Miller – Assistant Public Services Director	252-939-3285
Brian Lucas - Water Resources Manager	252-939-3316

Stormwater Utility:

Brian Lucas - Water Resources Manager	252-939-3316
Gilbert Aceveno - Street Superintendent	252-939-3314

Water Reclamation (Wastewater Utility):

Kenneth R. Stevens, Jr. - Water Reclamation Facility Superintendent (ORC)	252-939-3375
Swindell Flowers - Residual Management Coordinator (ORC-Land Application)	252-939-3248
Dan Daniels - Water Operations Superintendent (ORC - Wastewater Collections)	252-939-3299

Water Utility:

Joey Pittman - Water Production Superintendent (ORC-Wells)	252-939-3286
Dan Daniels - Water Operations Superintendent (ORC - Distribution)	252-939-3299
Kelvin Harrison - Water Production Supervisor (ORC-Cross Connection)	252-939-3156